

San Joaquin Valley Unified Air Pollution Control District

PERMIT UNIT: N-1662-13-1

EXPIRATION DATE: 6/30/2001

EQUIPMENT DESCRIPTION:

ONE (1) 95 HP CATERPILLAR NATURAL GAS FIRED IC ENGINE (MODEL 3304NG/SERIAL NO. 37Y00679) SERVING AN EMERGENCY BLOCK COOLING FAN

Permit Unit Requirements

1. Sulfur compound emissions shall not exceed 0.2% by volume, 2000ppmv, on a dry basis averaged over 15 consecutive minutes. [Rule 404 (Madera), 406 (Fresno) and 407 (6 remaining counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
2. Particulate emissions shall not exceed at the point of discharge, 0.1gr/dscf. [District Rule 4201; Rule 402 (Madera) and 404 (all 7 remaining counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
3. Unit shall be fired only on PUC quality natural gas with a sulfur content of less than or equal to 0.017% by weight. [Rule 404 (Madera), 406 (Fresno) and 407 (6 remaining counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
4. If the IC engine is fired on PUC-regulated natural gas, then maintain on file copies of all natural gas bills. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
5. If the engine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the IC engine shall be determined using ASTM method D 1072-80, D 3031-81, D 4084-82 or D 3246-81. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
6. If the engine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
7. The operator of an internal combustion (IC) engine shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2] Federally Enforceable Through Title V Permit
8. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements of SJVUAPCD Rule 4201; Rules 406 (Fresno), 404 (Madera), 407 (Kern, Kings, San Joaquin, Stanislaus, Merced, Tulare). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
9. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following subsumed requirements: Rules 402 (Madera) and 404 (Fresno, Merced, Kern, Kings, San Joaquin, Stanislaus, Tulare). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
10. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

